



Reply to the Attention of:

OCT 12 1995

Mr. Daniel Harkins  
President  
Simple Saver Plus, Inc.  
P.O. Box 324  
Stoughton, WI 53589

Dear Mr. Harkins:

This is in response to your September 11 letter requesting a letter of compliance from the Occupational Safety and Health Administration (OSHA) for your Simple Saver Plus System.

As you know, OSHA does not endorse products nor issue formal letters of approval for products or work procedures. However, when provided with sufficient information, OSHA can offer an opinion as to whether or not they afford compliance with certain regulations. We have reviewed the Simple Saver Plus fall protection information and test data and it appears that if the flexible fabric is installed as described in your specifications for materials and installation documents, the user would be in compliance with OSHA's fall protection requirements for falls to the interior of the structure. As we have discussed previously, employees exposed to falls to the exterior may (depending on the activity and fall height) have to be protected by a guard rail or other effective system.

If we can be of any further assistance, please contact me or Mr. Dale Cavanaugh of my staff at (202) 219-8136.

Sincerely,

Roy F. Gurnham, P.E., J.D.  
Director  
Office of Construction and Maritime  
Compliance Assistance